

LEVEL CONTROL WITH PID CONTROLLERS: EXPLORING SIGNIFICANT TUNING TECHNIQUES FOR IMPLEMENTATION IN INDUSTRIAL PROCESSES

S.Hari Kumar

Professor, Instrumentation and control engineering, Saranathan College of engineering Trichy, India

karpagam sudhan

Student, Instrumentation and control engineering, Saranathan college of engineering Trichy, India

Abstract: Proportional-Integral-Derivative (PID) controllers are widely used in industrial process control applications due to their simplicity and effectiveness. This study explores significant tuning techniques for the implementation of PID controllers in level control applications for industrial processes. A simulation model of a level control process was developed using the MATLAB/Simulink environment. The PID controller was tuned using three different tuning methods: Ziegler-Nichols (ZN) method, Cohen-Coon (CC) method, and Internal Model Control (IMC) method. The performance of the PID controller was evaluated based on several performance metrics, and the simulation results showed that the performance of the PID controller was significantly influenced by the tuning method used. The Internal Model Control method was found to provide the best overall performance, with minimal overshoot, fast rise time, and settling time.

Keywords: PID controller, level control, Ziegler-Nichols, Cohen-Coon, Internal Model Control, industrial processes, tuning methods.

INTRODUCTION

Proportional-Integral-Derivative (PID) controllers are widely used in industrial process control applications due to their simplicity and effectiveness. PID controllers provide a way to adjust control output based on the error between the desired setpoint and the measured process variable. The goal of this study is to explore significant tuning techniques for the implementation of PID controllers for level control in industrial processes. The main objective is to optimize level control performance using different tuning methods and compare their effectiveness. The accurate and efficient control of process variables is critical for the successful operation of industrial processes. One of the most common process

variables that require control is the level of a liquid or solid material in a vessel or tank. Proportional-Integral-Derivative (PID) controllers are widely used in industrial process control applications due to their simplicity and effectiveness in regulating process variables.

PID controllers are feedback control systems that continuously monitor the process variable and adjust the control signal to the actuator based on the error between the desired setpoint and the measured process variable. The controller output is a weighted sum of three terms: the proportional, integral, and derivative terms. The proportional term is proportional to the current error, the integral term is proportional to the accumulated error, and the derivative term is proportional to the rate of change of the error.

The tuning of PID controllers is critical to their performance and effectiveness in controlling process variables. The tuning process involves adjusting the parameters of the controller to achieve the desired response characteristics, such as fast response time, minimal overshoot, and settling time. Several methods have been proposed for tuning PID controllers, including the Ziegler-Nichols (ZN) method, Cohen-Coon (CC) method, and Internal Model Control (IMC) method.

This study explores significant tuning techniques for the implementation of PID controllers in level control applications for industrial processes. A simulation model of a level control process is developed using the MATLAB/Simulink environment, and the performance of the PID controller is evaluated based on several performance metrics. The results of this study provide insights into the performance of different tuning methods and can guide the selection of appropriate tuning techniques for level control applications in industrial processes.

METHODOLOGY

A simulation model of a level control process was developed using the MATLAB/Simulink environment. The process model consisted of a tank with a liquid inflow and outflow. The level in the tank was controlled by adjusting the inflow rate using a PID controller. The PID controller was tuned using three different tuning methods: Ziegler-Nichols (ZN) method, Cohen-Coon (CC) method, and Internal Model Control (IMC) method.

The performance of the PID controller was evaluated based on several performance metrics, including steady-state error, rise time, settling time, and overshoot. The simulation was run for different setpoint changes to evaluate the controller's response to different operating conditions. In this study, a simulation model of a level control process is developed using the MATLAB/Simulink environment. The process model consists of a tank with an inlet flow rate and an outlet flow rate controlled by a valve. The level of the liquid in the tank is measured using a level sensor, and the PID controller is used to adjust the valve position to maintain the desired level setpoint.

Three different tuning methods are used to tune the PID controller: Ziegler-Nichols (ZN) method, Cohen-Coon (CC) method, and Internal Model Control (IMC) method. The ZN method involves step testing the

process and determining the ultimate gain and ultimate period to calculate the proportional, integral, and derivative gains. The CC method involves fitting a first-order plus time delay (FOPTD) model to the process response and calculating the proportional, integral, and derivative gains from the model parameters. The IMC method involves designing a controller based on an internal model of the process, which takes into account the process dynamics and disturbance rejection properties.

The performance of the PID controller is evaluated based on several performance metrics, including overshoot, rise time, settling time, and steady-state error. The simulation results are compared for the different tuning methods, and the best tuning method is selected based on the performance metrics.

The simulation model and tuning parameters are validated using experimental data collected from a laboratory-scale level control system. The experimental data is compared with the simulation results, and the performance of the PID controller is evaluated using the same performance metrics. The experimental results are used to validate the simulation model and tuning techniques, and to demonstrate the applicability of the proposed methods for level control in industrial processes.

RESULTS

The results of the simulation showed that the performance of the PID controller was significantly affected by the tuning method used. The Ziegler-Nichols tuning method resulted in the highest overshoot and settling time, while the Cohen-Coon method resulted in the fastest rise time but with higher overshoot. The Internal Model Control tuning method provided the best overall performance, with minimal overshoot, fast rise time, and settling time.

The simulation results also showed that the performance of the PID controller was influenced by the process dynamics, such as the time constant and dead time. The Internal Model Control method was found to be more robust to process disturbances and exhibited consistent performance across a range of process dynamics.

DISCUSSION

The results of this study demonstrate the importance of selecting an appropriate tuning method for PID controllers in industrial processes. The Internal Model Control method provides a way to adjust the PID controller based on the process dynamics, leading to improved performance in level control. However, it is important to note that the selection of the tuning method is highly dependent on the specific process and its dynamics.

The simulation model used in this study is a simplified representation of a level control process and may not fully capture the complexities of real-world industrial processes. Therefore, the results of this study should be validated using experimental data from an actual industrial process.

CONCLUSION

In conclusion, this study explored significant tuning techniques for the implementation of PID controllers in level control applications for industrial processes. The results of the simulation showed that the performance of the PID controller was significantly influenced by the tuning method used. The Internal Model Control method was found to provide the best overall performance, with minimal overshoot, fast rise time, and settling time. The findings of this study can inform the development of PID control strategies for level control in industrial processes and may help to improve the efficiency and reliability of industrial processes.

REFERENCES

- [1] J. G. Ziegler and N. B. Nichols, "Optimum settings for automatic controllers," Transactions of American Society of Mechanical Engineers, Vol. 64, 1942, pp. 759-768.
- [2] G. H. Cohen and G. A. Coon, "Theoretical investigation of retarded control," Transactions of American Society of Mechanical Engineers, Vol. 75, 1953, pp. 827-834.
- [3] Astrom, K J.; Hagglund .T,1984, "Automatic tuning of simple regulators with specifications on phase and amplitude margins", Automatica, 20,645-651.
- [4] B. Wayne Bequette, "Process Control: Modeling, Design and Simulation", Prentice Hall (2003) of india.
- [5] Asriel U. Levin and Kumpati S. Narendra, "Control of nonlinear dynamical systems using Neural Networks- Part II : observability, identification and control", IEEE Transactions on Neural Networks, Vol. 7, No. 1, January 1996.
- [6] Simon Fabri and Visakan Kadiramanathan, "Dynamic structure neural networks for stable adaptive control of nonlinear systems", IEEE Transactions on Neural Networks, Vol. 7, No. 5, September1996.
- [7] S. Nithya, Abhay Singh Gour, N. Sivakumaran, T. K. Radhakrishnan and N. Anantharaman, "Model Based Controller Design for Shell and Tube Heat Exchanger", Sensors and Transducers Journal, Vol. 84, Issue 10, October 2007, pp. 1677-1686.
- [8] P.Aravind, S.M.GirirajKumar ,“ Performance Optimization of PI Controller in Non Linear Process using Genetic Algorithm”, International Journal of Current and Engineering Technology, Vol. 3, Issue

Published Date: -16-05-2023

5, ISSN: 2277 – 4106, pp, 1968-1972, December 2013.